

APPROVAL NO: 200909**APPROVAL DATE: 18/03/09****APPROVAL VALID UNTIL: 17/03/12****FILE NO: 2009/01267F**

COMPANY: ACP Australian Custom Pipes Pty Ltd
ADDRESS: 24A Alfred Road, Chipping Norton NSW 2170
CONTACT NAME: Mr Kevin Cox

PRODUCT DESCRIPTION: Polyethylene (PE) pressure pipe
PRODUCT SPECIFICATION: AS/NZS4130 / WSA PS-207
APPROVED APPLICATION: Pressure pipes conveying drinking water, recycled water or sewage (Note 3)
WSAA APPRAISAL NO: N/A

Conditions of Approval:

1. Continuation of JASANZ accredited 3rd party product certification to AS/NZS 4130.

Notes:

1. This approval may be withdrawn or modified at any time.
2. The pressure rating (PN) of PE pipe is dependent on particular project requirements, generally PN16. Nomination of the actual pressure is the responsibility of person(s) having project-specific authority.
3. Differentiation of product for drinking water, recycled water or sewage shall be in accordance with Water Services Association product specification WSA PS-207.
4. This approval does not apply to plumbing products regulated by the National Certification of Plumbing and Drainage Products Scheme.



Michael Hordern
Project Manager Engineering Standards