

Re-Issued to

## ACP (AUSTRALIAN CUSTOM PIPES PTY LTD)

Authorisation No:	18/003	Standards Mark Ref:	AMI 74863
Australian Standard:	AS/NZS 4130:2009	WSAA Product Appraisal No:	PA 1731
Other Standards:	AS/ NZS 4020	Product Authorisation Date:	31/05/18

### Product Description

**Product Type/ Rating** PE 100 Series 1 Pipe, PN 16  
**Size Range** ODs 25, 50, 63, 125, 180, 250, 315

### Conditions

- Where a range of items or sizes are involved, this Authorisation applies only to those items or sizes listed in the SA Water corporation, Authorised Items Catalogue.
- This Authorisation does not refer to the effectiveness of the product and no claim shall be made through advertising, promotion or in any other way that the above products have been authorised or tested by the corporation in other than the terms of this authorisation.
- The items described above are authorised for use in SA Water's Infrastructure systems, in accordance with the Corporations Construction Documentation and shall be manufactured under a third party certified Quality Assurance System. All products shall be identified with the manufacturers name or trade mark.
- AUSTRALIAN CUSTOM PIPES PTY LTD shall be responsible for assuring the quality of the approved products that are supplied to the market. Where approved products or parts thereof are manufactured or assembled by a third party, AUSTRALIAN CUSTOM PIPES PTY LTD shall employ systematic procedures to verify product conformance.
- The products shall be manufactured under a third-party certified Quality Assurance System. All products shall be identified by the manufacturers name or trade mark.
- The products shall demonstrate satisfactory performance when installed in SA Water's infrastructure system.
- The Corporation shall be notified in writing if;
  - the third party ISO 9001 certification is withdrawn, suspended or changed,
  - any change of the certification agency occurs,
  - there are any changes to product design, materials, model numbers, etc or
  - the products are to be withdrawn from sale.
  - the five yearly AS/NZS 4020 product compliance testing, has been completed.
- The products may be subjected to random quality control checks for which a sample may be required, and a charge may apply. Compliance with new Standards as they are replaced will need to be demonstrated by the manufacturer.
- SA Water reserves the right to request additional information and/ or evidence of product suitability SA Water reserves the right to modify or withdraw any authorised product or material from its Technical Standards or other published documents, for any reason it deems appropriate.

Authorised by. Kevin Claridge

Date. 15/07/2024